

Standards Revisions Related to the Life Safety Code for Nursing Care Center Accreditation Programs

The Joint Commission has approved the following revisions for prepublication. While revised requirements are published in the semiannual updates to the print manuals (as well as in the online E-dition®), certified organizations and paid subscribers can also view them in the monthly periodical The Joint Commission Perspectives®. To begin your subscription, call 800-746-6578 or visit <http://www.jcrinc.com>.

Standard LS.02.01.30

The organization provides and maintains building features to protect individuals from the hazards of fire and smoke.

Element(s) of Performance for LS.02.01.30

13. In existing buildings, all corridor doors are constructed of 1 3/4-inch or thicker solid bonded wood core or constructed to resist fire for not less than 20 minutes, and the doors do not have ventilating louvers or transfer grills (with the exception of bathrooms, toilets, and sink closets that do not contain flammable or combustible materials). Positive latching hardware is required. Roller latches are prohibited.

~~Note: For existing doors, it is acceptable to use a device that keeps the door closed when a force of five pounds is applied to the edge of the door. (For full text, refer to NFPA 101-2012: 19.3.6.3.1; 19.3.6.3.2; 19.3.6.3.5; 19.3.6.3.6)~~

13. In existing buildings, all corridor doors are **constructed to resist the passage of smoke and constructed of 1 3/4-inch or thicker solid bonded wood core or constructed of material that resists fire for not less than 20 minutes, and the doors do not have ventilating louvers or transfer grills (with the exception of bathrooms, toilets, and sink closets that do not contain flammable or combustible materials). Positive latching hardware is required.** Roller latches are prohibited. (For full text, refer to NFPA 101-2012: 19.3.6.3.1; 19.3.6.3.2; 19.3.6.3.5)